

# Application for Connections to the City Water & Sanitary Sewer Systems

NAME \_\_\_\_\_ DATE \_\_\_\_\_

ADDRESS \_\_\_\_\_ PH.# \_\_\_\_\_

ADDRESS OF PROPOSED WORK \_\_\_\_\_

NAME OF CONTRACTOR TO PERFORM WORK \_\_\_\_\_

CONTRACTOR'S ADDRESS \_\_\_\_\_ PH.# \_\_\_\_\_

\*Water Service Size \_\_\_\_\_ \*Water Service Material \_\_\_\_\_

\*Sewer Service Size \_\_\_\_\_ \*Sewer Service Material \_\_\_\_\_

*\*The applicant must have a GOPHER STATE ONE CALL (GSOC) ticket number assigned before work can begin. The GSOC ph. # is 1-800-252-1166. GSOC will notify any utilities in the area of the project. The GSOC call must be made at least 48 hrs. (excluding weekends, holidays, and emergencies) prior to the start of digging.*

*Nothing in this application shall be construed to imply that permission is granted to run a water or sewer line across another person's or owner's property. The applicant shall be responsible for obtaining any necessary easements or written agreements if running a private water or sewer line across another person's or owner's property. The applicant is also responsible for maintaining the line from the City's main to the home or building in good working order and making any and all repairs as required and necessary. **THE CITY CANNOT GRANT AN EASEMENT TO CROSS ANOTHER PERSONS PROPERTY.***

*Your Gopher One Call Ticket Number is: \_\_\_\_\_*

### Special Provisions

1. The water and sewer service pipe shall be sized in accordance with the requirements of the Minnesota Plumbing Code as of the date of installation.
2. Water service lines and pipes shall be Type-K copper unless different medium is authorized by the City Council after consideration and recommendations by the Utilities Commission.
3. Multiple connections may be constructed only after a set of detailed drawings of the system is submitted to the Utilities Commission and approved by the Council.
4. Water and sewer service piping shall be installed below the normal frost penetration level unless special provisions are made to prevent freezing.
5. No splice of a water service line shall be allowed under a road surface. There shall be no more than one splice allowed per 60 feet of flexible copper tubing.
6. See "Special Provisions" on Page 1 of this application when excavating in the road right-of-way.
7. It shall be the duty of the plumbing contractor to notify the proper administrative authority for the City so work can be inspected or tested before the sewer and/or lines are covered.

**The undersigned herewith agrees to comply with standards set by the Department of Health, the Minnesota Plumbing Code, and the City of Jackson as they relate to this application. No work can commence until appropriate connection fees are paid and the application is approved in writing by the local Water/Wastewater Authority.**

\$ \_\_\_\_\_  
Connection Fee(s)

\_\_\_\_\_  
Applicant's Signature

\_\_\_\_\_  
Date

**PRE-APPROVAL**  
\_\_\_\_\_  
Street Department/Wastewater Supervisor

\_\_\_\_\_  
Water Supervisor

### FINAL APPROVAL

\_\_\_\_\_  
Approval of Water Department Supervisor

\_\_\_\_\_  
Date

\_\_\_\_\_  
Approval of Street/Wastewater Supervisor

\_\_\_\_\_  
Date